

CERTIFICATE OF COMPLIANCE

Certificate Number 20161111-MH25998
Report Reference MH25998-19980902
Issue Date 2016-NOVEMBER-11

Issued to: VPI Precision Holdings L L C
5727 Superior Dr
Morristown TN 37814

**This is to certify that
representative samples of**

GAS-OIL-FIRED BOILER ASSEMBLIES
BOILER ASSEMBLIES WITH REDUCED EMISSIONS
GAS-FIRED BOILER ASSEMBLIES
OIL-FIRED BOILER ASSEMBLIES
Refer to Addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 2096 - Commercial/Industrial Gas and/or Oil-Burning
Assemblies With Emission Reduction Equipment

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20161111-MH25998
Report Reference MH25998-19980902
Issue Date 2016-NOVEMBER-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL - Gas, Oil, and Gas-Oil Fired Steam Boilers, Model FPS Series, and Gas, Oil, and Gas-Oil Fired Water Boilers, Model FPH Series. All models may be provided with an induced flue gas recirculation system. All models are followed by suffix letters and/or numbers.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20161111-MH25998
Report Reference MH25998-19950901
Issue Date 2016-NOVEMBER-11

Issued to: VPI Precision Holdings L L C
5727 Superior Dr
Morristown TN 37814

**This is to certify that
representative samples of**

GAS-OIL-FIRED BOILER ASSEMBLIES
BOILER ASSEMBLIES WITH REDUCED EMISSIONS
GAS-FIRED BOILER ASSEMBLIES
OIL-FIRED BOILER ASSEMBLIES
Refer to Addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 2096 - Commercial/Industrial Gas and/or Oil-Burning
Assemblies With Emission Reduction Equipment

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20161111-MH25998
Report Reference MH25998-19950901
Issue Date 2016-NOVEMBER-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL Models 10, 15, 20, 25, 30, 40, 50, 60, 80, 100, 125, 150, 175, 200, 250, 300, 350, and 400 gas, oil, and gas-oil-fired boiler assemblies. Model designations include prefix letters and suffix numbers.

USL Models 10, 15, 20, 25, 30, 40, 50, 60, 80, 100, 125, 150, 175, 200, 250, 300, 350, and 400 gas fired boiler assemblies with emission reduction equipment. Model designations include prefix letters and suffix numbers.

USL Models 10, 15, 20, 25, 30, 40, 50, 60, 80, 100, 125, 150, 175, 200, 250, 300, 350, and 400 gas-oil-fired boiler assemblies with emission reduction equipment. Model designations include prefix letters and suffix numbers.

- The emission reduction equipment is operative firing gas only. See ILL. 8 for typical wiring diagram designating emission reduction equipment inoperative firing oil.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

